

南投縣境內淨水場101年度飲用水處理藥劑檢測結果彙整表

處理藥劑		次氯酸鈉 (俗稱：漂白水)						聚氯化鋁						
檢測項目		砷 (As)	鎘 (Cd)	鉻 (Cr)	汞 (Hg)	鉛 (Pb)	溴酸鹽 (Bromate)	砷 (As)	鎘 (Cd)	鉻 (Cr)	鐵 (Fe)	汞 (Hg)	錳 (Mn)	鉛 (Pb)
檢測日期	淨水場名稱	1 ppm	1 ppm	2 ppm	0.2 ppm	1 ppm	50 ppm	5 ppm	2 ppm	10 ppm	100 ppm	0.2 ppm	25 ppm	10 ppm
101.10.22	大平頂淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	14.5							
101.10.22	大旗尾淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	12.9							
101.10.22	草屯第一淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	14.3							
101.10.22	粗坑淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	16.4							
101.10.22	南崗淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	14.6							
101.10.23	瑞竹淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	18.7							
101.10.23	坪頂淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	20							
101.10.23	鹿谷淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	15.7	N.D.	N.D.	N.D.	5.17	N.D.	N.D.	N.D.
101.10.24	集集淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	14.0	N.D.	N.D.	N.D.	5.20	N.D.	N.D.	N.D.
101.10.24	羅娜淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	15.2							
101.10.24	信義淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	14.8							
101.10.24	水里淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	14.2	N.D.	N.D.	N.D.	5.98	0.01	N.D.	N.D.