

南投縣境內淨水場107年飲用水處理藥劑檢測結果彙整表

處理藥劑		次氯酸鈉 (俗稱：漂白水)					聚氯化鋁							
檢測日期	淨水場名稱	砷	鎘	鉛	汞	鉻	溴酸鹽	砷	鎘	鉛	汞	鉻	鐵	錳
		(As)	(Cd)	(Pb)	(Hg)	(Cr)	(Bromate)	(As)	(Cd)	(Pb)	(Hg)	(Cr)	(Fe)	(Mn)
		1	1	1	0.2	2	50	5	2	10	0.2	10	100	25
		ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm
107.10.01	草屯第一淨水場	<0.24	<0.03	<0.24	<0.013	<0.08	8.93							
	南崗淨水場	<0.24	<0.03	<0.24	<0.013	<0.08	9.81							
	粗坑淨水場	<0.24	<0.03	<0.24	<0.013	<0.08	14.4	<3.00	<0.40	<3.00	<0.013	<1.00	24.2	5.04
107.10.02	坪頂淨水場	<0.24	<0.03	<0.24	<0.013	<0.08	15.8							
	瑞竹淨水場	<0.24	<0.03	<0.24	<0.013	<0.08	11.3							
	鹿谷淨水場	<0.24	<0.03	<0.24	<0.013	<0.08	18.4	<3.00	<0.40	<3.00	<0.013	<1.00	27.3	7.89
107.10.03	大坪頂淨水場	<0.24	<0.03	<0.24	<0.013	<0.08	12.5							
	大旗尾淨水場	<0.24	<0.03	<0.24	<0.013	<0.08	15.1	<3.00	<0.40	<3.00	<0.013	<1.00	23.5	4.48
107.10.09	水里淨水場	<0.24	<0.03	<0.24	<0.013	<0.08	7.11	<3.00	<0.40	<3.00	<0.013	<1.00	24.4	6.02
	信義淨水場	<0.24	<0.03	<0.24	<0.013	<0.08	7.98							
	羅娜淨水場	<0.24	<0.03	<0.24	<0.013	<0.08	14.4	<3.00	<0.40	<3.00	<0.013	<1.00	29.5	5.78
	集集淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	7.59	<3.00	<0.40	<3.00	<0.013	<1.00	28.6	7.22