

南投縣境內淨水場105年飲用水處理藥劑檢測結果彙整表

處理藥劑		次氯酸鈉（俗稱：漂白水）					聚氯化鋁							
檢測項目		砷（As） 1 ppm	鎘（Cd） 1 ppm	鉻（Cr） 2 ppm	汞（Hg） 0.2 ppm	鉛（Pb） 1 ppm	溴酸鹽 （Bromate） 50 ppm	砷（As） 5 ppm	鎘（Cd） 2 ppm	鉻（Cr） 10 ppm	鐵（Fe） 100 ppm	汞（Hg） 0.2 ppm	錳（Mn） 25 ppm	鉛（Pb） 10 ppm
檢測日期	淨水場名稱													
105.10.17	營盤口淨水廠	N.D.	N.D.	N.D.	N.D.	N.D.	14.3							
	林子頭淨水廠	N.D.	N.D.	N.D.	N.D.	N.D.	14							
	草屯第三淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	11.1							
	草屯第二淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	17.2							
	草屯第四淨水場	N.D.	N.D.	0.19	N.D.	N.D.	16.8							
105.10.18	集集淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	10.6	N.D.	N.D.	N.D.	23.9	N.D.	7.1	N.D.
	水里淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	12.8	N.D.	N.D.	N.D.	26.8	N.D.	10.7	N.D.
	人倫淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	18.7	N.D.	N.D.	N.D.	26.1	N.D.	5.78	N.D.
	民和淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	14.0							
104.10.19	南崗淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	3.35							
	三興淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	17.5							
	嘉和第二淨水場	N.D.	N.D.	N.D.	N.D.	N.D.	14.8							